



**GENERAL:** This document defines **SIGNUM 120 Minute Steel Fire Resistant Sliding Door specifications** which meet with **IS 3614 and BS 476 Part 22** standards for Fire Resistance. The product described herein **conforms to stability as well as integrity criteria** as mentioned in IS 3614/ BS 476 Part 22. It includes proprietary design and performance specifications.

#### REFERENCES

**IS 513:** Cold Reduced Low Carbon Steel Sheet and Strip

**IS 277:** Galvanized Steel Sheets (Plain and Corrugated) – Specification

**IS 4923:** Hollow Steel Sections for Structural Use - Specification

**IS 3614:** Fire Doors and Doorsets - Specification

**BS 476 Part 22:** Fire Resistance Test to Building Material – Non load-bearing elements of construction

**IS 13871:** Powder Coatings - Specification

#### MATERIALS

Steel sheets for frame sections and shutter skin shall conform to IS 277 with Z 120 coating and to IS 513 for its base physical and chemical properties.

Steel pipe for internal structure of shutter and overhead track as per design conforming to IS 4923

Shutter core shall be proprietary fire retardant heat insulating material

MS Plate of various thicknesses shall be used to make other accessories

Vision Panel (optional) shall be of necessary construction to achieve a fire rating of 120 minutes as per standards

#### CONSTRUCTION

**Shutter:** Steel shutters shall be 66 mm ( $\pm 5$  mm) thick, with profiled sheet welded on both sides of steel pipe structure.

Shutters shall be provided with proprietary fire retardant heat insulating core to be bonded to the inner surfaces of the shutter using suitable permanent glue.

Shutters shall be factory prepared with pre-punched cut-outs and reinforcements to receive iron mongery. Flame baffles shall be welded on shutter as per direction of opening.

Shutters shall be factory prepared with pre-punched cut-outs and reinforcements to receive iron mongery.

The sliding door shall have dimensions such that it overlaps the top side of the civil/ structural opening by at least 100 mm and each horizontal side by at least 100 mm (total 200 mm), depending on the overall size of the opening, intent of the door and location.

A hinged type Wicket door, if required shall be supplied as per specifications for same fire rating as that of sliding door. The frame for the wicket door shall be of single rebated profile of 66 x 44 mm and shall be fixed onto the sliding panel at location as specified. The shutter shall be 50 mm thick and fixed to the frame using suitable hinges and lock. Various other iron mongery provisions can be made on the wicket door/ sliding panel such as for door closers etc.

**Track:** Shutter track shall be constructed from suitable steel structure and shall be factory prepared with cut-out for hanging of sliding shutter. One end of track shall be closed by welding plate and buffer while the other end shall have provision to fix end plate using nut-bolts.

**Accessories:** Track support, trolley, hangar, flame baffles, bottom guide roller, rope pulley support, counter-weight support and cage shall be made as per our standard design.

#### FABRICATION

Steel shutter, Track, Trolley, Hanger, Flame Baffles and other accessories shall be fabricated to be rigid and free from defects such as warping and buckling.

Flange for vision panel (**optional**) shall be square or rectangular in shape with a profile of 40 x 6 mm, with one side welded to the shutter face and the other side screwed. Screws shall be counter sunk and flat to be flush with beading surface.

#### FINISHES

Steel shutter, Track, Trolley, Hanger, Flame Baffles and other accessory surfaces shall be suitably prepared and cleaned with solvents prior to coating. Sliding Door shall be finished powder coated at factory as per approve RAL colour shades. The dry film thickness (DFT) for the powder coating shall be not less than 50 microns as per IS 13871.

Alternatively the Sliding Door can be finished using anticorrosive zinc rich two component epoxy stoving primer (35 microns DFT) and top coat of two component polyurethane paint (35 microns DFT) of approved RAL colour shade for the project



### **QUALITY ASSURANCE**

Steel Fire rated Sliding doors shall be manufactured by a unit certified for its quality systems as per ISO 9001: 2015 standards from a recognized certifying authority.

Sliding door shall be designed and manufactured to comply with IS 3614 specifications.

Each door unit shall have a fire rating label, to indicate fire resistance of door as well as door identification number and date of manufacturing.

Sliding door shall be GreenPro certified to be eco-friendly by CII-IGBC (Indian Green Building Council).

### **TESTING**

Entire sliding door assembly complete with accessories shall be type tested and certified for its fire rating by CBRI or CPRI. Type test reports shall be submitted for all projects with no further testing required, unless agreed to between the client and SIGNUM.

### **WARRANTY**

SIGNUM warrants that for 18 months from the date of dispatch or 12 months from the date of installation, whichever is earlier, its manufactured products shall be free from defects in material, workmanship and construction and in accordance with the approved shop drawings submitted. Any items not manufactured by SIGNUM are only as warranted by the manufacturer of such items, otherwise all such items are sold on an AS IS basis. If examination by SIGNUM discloses that the product has been defective, provided the product was used as intended and appropriately maintained, then our obligation is limited to repair or replacement, at our option, of the defective parts or entire product, free of charge to the client. Manufacturer's warranty shall exclude losses caused by improper or insufficient maintenance, normal wear and tear, any improper operating, storage, handling, installation, modification after handing over of product to client. Manufacturer's liability for incidental, consequential, or damages, including commercial or other loss, resulting from any defective product, is strictly limited to repair and/ or replacement as stated above. For details please feel free to contact us:

#### **SIGNUM FIRE PROTECTION INDIA PVT. LTD.**

PH No. 6, KH No. 202/2, Village Waddhamana,

Taluka Hingna, NAGPUR 440023 INDIA

Ph: +91 7104 289289, Email: [marketing@signum.co.in](mailto:marketing@signum.co.in)

### **TRANSPORTATION, UNLOADING AND STORAGE**

Sliding Doors shall be covered with adhesive based PE sheets to prevent damages to surface finish during transportation and at site. Labels shall be applied to each set as per project schedule for easy identification at site.

Additional protection such as side bolsters from card-board paper shall be used to protect during transit and at-site storage.

Track along with flame baffles shall be covered with PE film. All other accessories shall be packed in wooden crates. Signum recommends storage in clean, dry, well-ventilated areas.

**DISCLAIMER:** All functionality, features, specifications and other product information provided in this document including, but not limited to design, components, performance, availability and capabilities of the product are subject to change without notice or obligation.

# SIGNUM